



AQUA PRO-TECH LABORATORIES
 Certified Environmental Testing

Client: BANYAN SCHOOL
 12 Hollywood Ave.
 Fairfield, NJ 07004

APL Order ID Number: 2030648
 Collected : 03/07/2022 8:00
 Received: 03/11/2022

Contact:
 Client Project: Banyan School

Contact: 03/25/2022 10:21
 Customer Service Rep: Tony Tudda

Analytical Results Summary

Sample Number Analyte	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
2030648-01	Drinking Water	BOYS ROOM SINK 1						
Total Metals								
Copper	EPA 200.8	3/19/22 18:59	3/19/22 18:59	0.222			0.00200	mg/L
Lead	EPA 200.8	3/19/22 18:59	3/19/22 18:59	0.0109			0.00200	mg/L
2030648-02	Drinking Water	GIRLS ROOM SINK 1						
Total Metals								
Copper	EPA 200.8	3/19/22 19:01	3/19/22 19:01	0.192			0.00200	mg/L
Lead	EPA 200.8	3/19/22 19:01	3/19/22 19:01	0.00245			0.00200	mg/L
2030648-03	Drinking Water	GIRLS ROOM SINK 2						
Total Metals								
Copper	EPA 200.8	3/19/22 19:04	3/19/22 19:04	0.117			0.00200	mg/L
Lead	EPA 200.8	3/19/22 19:04	3/19/22 19:04	< 0.00200	U		0.00200	mg/L
2030648-04	Drinking Water	LADIES ROOM NEAR GYM SINK 2						
Total Metals								
Copper	EPA 200.8	3/19/22 19:06	3/19/22 19:06	0.112			0.00200	mg/L
Lead	EPA 200.8	3/19/22 19:06	3/19/22 19:06	0.00393			0.00200	mg/L
2030648-05	Drinking Water	KITCHEN SINK						
Total Metals								
Copper	EPA 200.8	3/19/22 19:08	3/19/22 19:08	0.0879			0.00200	mg/L
Lead	EPA 200.8	3/19/22 19:08	3/19/22 19:08	< 0.00200	U		0.00200	mg/L

Brian Wood
 Laboratory Director

Analytical Results Summary

Sample Number Analyte	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
2030648-06	Drinking Water	SLOPSINK NEAR GYM						
Total Metals								
Copper	EPA 200.8	3/19/22 19:11	3/19/22 19:11	0.272			0.00200	mg/L
Lead	EPA 200.8	3/19/22 19:11	3/19/22 19:11	< 0.00200	U		0.00200	mg/L
2030648-07	Drinking Water	O'CONNOR HALL FOUNTAIN						
Total Metals								
Copper	EPA 200.8	3/19/22 19:18	3/19/22 19:18	0.146			0.00200	mg/L
Lead	EPA 200.8	3/19/22 19:18	3/19/22 19:18	< 0.00200	U		0.00200	mg/L
2030648-08	Drinking Water	BOYS RM SINK 3						
Total Metals								
Copper	EPA 200.8	3/19/22 19:20	3/19/22 19:20	0.0878			0.00200	mg/L
Lead	EPA 200.8	3/19/22 19:20	3/19/22 19:20	< 0.00200	U		0.00200	mg/L
2030648-09	Drinking Water	MENS RM NEAR GYM SINK 1						
Total Metals								
Copper	EPA 200.8	3/19/22 19:23	3/19/22 19:23	0.0948			0.00200	mg/L
Lead	EPA 200.8	3/19/22 19:23	3/19/22 19:23	< 0.00200	U		0.00200	mg/L
2030648-10	Drinking Water	BOYS ROOM SINK 2						
Total Metals								
Copper	EPA 200.8	3/19/22 19:25	3/19/22 19:25	0.130			0.00200	mg/L
Lead	EPA 200.8	3/19/22 19:25	3/19/22 19:25	0.00264			0.00200	mg/L
2030648-11	Drinking Water	NURSE SINK						
Total Metals								
Copper	EPA 200.8	3/19/22 19:32	3/19/22 19:32	0.119			0.00200	mg/L
Lead	EPA 200.8	3/19/22 19:32	3/19/22 19:32	< 0.00200	U		0.00200	mg/L
2030648-12	Drinking Water	MENS RM BY O'CONNORS						
Total Metals								
Copper	EPA 200.8	3/19/22 19:35	3/19/22 19:35	0.0616			0.00200	mg/L
Lead	EPA 200.8	3/19/22 19:35	3/19/22 19:35	< 0.00200	U		0.00200	mg/L
2030648-13	Drinking Water	MENS RM NEAR GYM SINK 2						
Total Metals								
Copper	EPA 200.8	3/19/22 19:37	3/19/22 19:37	0.110			0.00200	mg/L
Lead	EPA 200.8	3/19/22 19:37	3/19/22 19:37	0.00369			0.00200	mg/L
2030648-14	Drinking Water	GIRLS BATHROOM SINK 3						

Brian Wood
Laboratory Director



Analytical Results Summary

Sample Number Analyte	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
2030648-14	Drinking Water	GIRLS BATHROOM SINK 3						
Total Metals								
Copper	EPA 200.8	3/19/22 19:39	3/19/22 19:39	0.133			0.00200	mg/L
Lead	EPA 200.8	3/19/22 19:39	3/19/22 19:39	< 0.00200	U		0.00200	mg/L
2030648-15	Drinking Water	LADIE RM NEAR GYM SINK 1						
Total Metals								
Copper	EPA 200.8	3/19/22 19:42	3/19/22 19:42	0.0889			0.00200	mg/L
Lead	EPA 200.8	3/19/22 19:42	3/19/22 19:42	0.00537			0.00200	mg/L
2030648-16	Drinking Water	WOMENS RM BY O CONNORS SINK						
Total Metals								
Copper	EPA 200.8	3/19/22 19:44	3/19/22 19:44	0.0836			0.00200	mg/L
Lead	EPA 200.8	3/19/22 19:44	3/19/22 19:44	0.00731			0.00200	mg/L

FootNotes

RL - Reporting limit
 MDL - Minimum detection limit
 ND, U - Indicates compound analyzed for but not detected
 J - Indicates estimated value

B - Indicates compound found in associated blank
 E - Concentration exceeds highest calibration standard
 D - Indicates result is based on a dilution
 P - Greater than 25% diff. between 2 GC columns
 H - Indicates a Hold Time violation
 D1 - Sample was Decanted (Dissolved)

Brian Wood
 Laboratory Director

