



AQUA PRO-TECH LABORATORIES
 Certified Environmental Testing

Client: BANYAN SCHOOL
 471 MAIN STREET
 LITTLE FALLS, NJ 07424

APL Order ID Number: 2030644
 Collected : 03/11/2022 6:50
 Received: 03/11/2022

Contact:
 Client Project: BANYAN SCHOOL

Contact: 03/25/2022 10:12
 Customer Service Rep: Tony Tudda

Analytical Results Summary

Sample Number	Analyte	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
2030644-01	Drinking Water		TIMM CTR. KITCHEN SINK						
Total Metals									
Copper		EPA 200.8	3/19/22 18:28	3/19/22 18:28	0.0640			0.00200	mg/L
Lead		EPA 200.8	3/19/22 18:28	3/19/22 18:28	< 0.00200	U		0.00200	mg/L
2030644-02	Drinking Water		TIMM CTR. BATHROOM SINK						
Total Metals									
Copper		EPA 200.8	3/19/22 18:31	3/19/22 18:31	0.0454			0.00200	mg/L
Lead		EPA 200.8	3/19/22 18:31	3/19/22 18:31	< 0.00200	U		0.00200	mg/L
2030644-03	Drinking Water		BASEMENT KITCH SINK 1						
Total Metals									
Copper		EPA 200.8	3/19/22 18:33	3/19/22 18:33	0.106			0.00200	mg/L
Lead		EPA 200.8	3/19/22 18:33	3/19/22 18:33	0.00232			0.00200	mg/L
2030644-04	Drinking Water		BASEMENT BOYS SINK						
Total Metals									
Copper		EPA 200.8	3/19/22 18:35	3/19/22 18:35	0.0549			0.00200	mg/L
Lead		EPA 200.8	3/19/22 18:35	3/19/22 18:35	< 0.00200	U		0.00200	mg/L
2030644-05	Drinking Water		BASEMENT KITCH SINK 2						
Total Metals									
Copper		EPA 200.8	3/19/22 18:38	3/19/22 18:38	0.122			0.00200	mg/L
Lead		EPA 200.8	3/19/22 18:38	3/19/22 18:38	0.00344			0.00200	mg/L

Brian Wood
 Laboratory Director

Analytical Results Summary

Sample Number Analyte	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
2030644-06	Drinking Water	BASEMENT GIRLS SINK						
Total Metals								
Copper	EPA 200.8	3/19/22 18:40	3/19/22 18:40	0.0703			0.00200	mg/L
Lead	EPA 200.8	3/19/22 18:40	3/19/22 18:40	< 0.00200	U		0.00200	mg/L
2030644-07	Drinking Water	2ND FLOOR GIRLS SINK 1						
Total Metals								
Copper	EPA 200.8	3/19/22 18:42	3/19/22 18:42	0.0534			0.00200	mg/L
Lead	EPA 200.8	3/19/22 18:42	3/19/22 18:42	< 0.00200	U		0.00200	mg/L
2030644-08	Drinking Water	2ND FLOOR GIRLS SINK 2						
Total Metals								
Copper	EPA 200.8	3/19/22 18:50	3/19/22 18:50	0.0459			0.00200	mg/L
Lead	EPA 200.8	3/19/22 18:50	3/19/22 18:50	< 0.00200	U		0.00200	mg/L
2030644-09	Drinking Water	2ND FLOOR STAFF LOUNGE						
Total Metals								
Copper	EPA 200.8	3/19/22 18:52	3/19/22 18:52	0.0702			0.00200	mg/L
Lead	EPA 200.8	3/19/22 18:52	3/19/22 18:52	< 0.00200	U		0.00200	mg/L
2030644-10	Drinking Water	2ND FLOOR NURSES BATHR. SINK						
Total Metals								
Copper	EPA 200.8	3/19/22 18:54	3/19/22 18:54	0.0978			0.00200	mg/L
Lead	EPA 200.8	3/19/22 18:54	3/19/22 18:54	< 0.00200	U		0.00200	mg/L
2030644-11	Drinking Water	1ST FLOOR STAFF BATHROOM SINK						
Total Metals								
Copper	EPA 200.8	3/19/22 18:57	3/19/22 18:57	0.0755			0.00200	mg/L
Lead	EPA 200.8	3/19/22 18:57	3/19/22 18:57	< 0.00200	U		0.00200	mg/L

FootNotes

RL - Reporting limit
 MDL - Minimum detection limit
 ND, U - Indicates compound analyzed for but not detected
 J - Indicates estimated value

B - Indicates compound found in associated blank
 E - Concentration exceeds highest calibration standard
 D - Indicates result is based on a dilution
 P - Greater than 25% diff. between 2 GC columns
 H - Indicates a Hold Time violation
 D1 - Sample was Decanted (Dissolved)

Brian Wood
 Laboratory Director

